

# Town of Prescott Drinking Water System

---

Waterworks # 220001245  
System Category – Large Municipal Residential

## 2025 Annual Water Report

Prepared For: Town of Prescott

Reporting Period of January 1<sup>st</sup> – December 31<sup>st</sup> 2025

Issued: February 18, 2026

Revision: 0

Operating Authority:



This report has been prepared to satisfy the annual reporting requirements in O.Reg 170/03 Section 11 and Schedule 22

## Table of Contents

<b>Revision History</b> .....	<b>1</b>
<b>Report Availability</b> .....	<b>1</b>
<b>Compliance Report Card</b> .....	<b>1</b>
<b>System Process Description</b> .....	<b>2</b>
Raw Source .....	2
Treatment.....	2
Distribution.....	2
<b>Summary of Non-Compliance</b> .....	<b>3</b>
Adverse Water Quality Incidents.....	3
Non-Compliance .....	3
Non-Compliance Identified in a Ministry Inspection:.....	3
Community Complaints .....	3
<b>Flows</b> .....	<b>4</b>
Raw Water Flows.....	4
Treated Water Flows .....	5
<b>Regulatory Sample Results Summary</b> .....	<b>6</b>
Microbiological Testing.....	6
Operational Testing .....	6
Inorganic Parameters .....	6
Organic Parameters .....	8
Additional Legislated Samples.....	9
<b>Major Maintenance Summary</b> .....	<b>9</b>
Distribution Maintenance.....	10
<b>WTRS Data and Submission Confirmation</b> .....	<b>A</b>

## Revision History

Date	Revision #	Revision Notes
February 18, 2026	0	Annual report issued

## Report Availability

This system does not serve more than 10,000 residence and the annual reports will be available to residents at the Town Hall located at 360 Dibble Street West, Prescott, Ontario, as well as on the Town website. ([www.prescott.ca](http://www.prescott.ca)) Copies are provided free of charge if requested.

## Compliance Report Card

Compliance Event	# of Events
Ministry of Environment Inspections	<ul style="list-style-type: none"> <li>- 1 Ministry Inspection on February 14, 2025</li> <li>- Final Inspection Rating: 100%</li> </ul>
Ministry of Labour Inspections	<ul style="list-style-type: none"> <li>- No Ministry of Labour inspections in 2025</li> </ul>
QEMS External Audit	<ul style="list-style-type: none"> <li>- 1 QEMS Audit on April 25, 2025</li> </ul>
AWQI's/BWA	<ul style="list-style-type: none"> <li>- 5 AWQI's, Sample cross contamination in cooler</li> </ul>
Non-Compliance	<ul style="list-style-type: none"> <li>- No Non-compliance in 2025</li> </ul>
Community Complaints	<ul style="list-style-type: none"> <li>- 8 community complaints referenced in report</li> </ul>
Spills	<ul style="list-style-type: none"> <li>- No spills in 2025</li> </ul>
Watermain Breaks	<ul style="list-style-type: none"> <li>- 6 water main breaks repaired in 2025</li> </ul>

## System Process Description

### Raw Source

Water is drawn from the St. Lawrence River into the plant via a 600 mm diameter steel intake pipe equipped with a sodium hypochlorite feed system for zebra mussel control. Raw water passes through a travelling screen unit located in the low lift building. The unit consists of wire mesh screens on a rotating belt. From there it is pumped to the plant for treatment.

### Treatment

Once water enters the plant, an aluminum based coagulant is added and flash mixed. The water then travels to flocculation tanks where the coagulant is allowed time to attract fine particles from the water. From there, the water passes through one of three dual media rapid sand filters. Sodium hypochlorite and hydrofluosilicic acid are added as water enters the clearwell. To maximize contact time, the treated water is diverted to two baffled reservoirs, each with a capacity of 800 m<sup>3</sup>. Four vertical turbine pumps are available for supplying the distribution demand as needed.

#### *Treatment Chemicals used during the reporting year:*

Chemical Name	Use	Supplier
Aluminum Sulphate	Coagulant	Kemira
Hydrofluosilicic Acid	Fluoridation	Univar
Sodium Hypochlorite	Disinfection	UBA

### Distribution

Watermains in the distribution system are composed of PVC, cast iron and ductile iron. An elevated storage tank is located on Sophia Street and has a storage capacity of 4200 m<sup>3</sup>. The storage facility provides for peak hour demands and fire flows.

## Summary of Non-Compliance

### Adverse Water Quality Incidents

Date	AWQI #	Location	Problem	Details	Legislation	Corrective Action Taken
07/15/25	169010 169011 169012 169013 169014	Prescott DWS	E.Coli/ Total Coliform	Cross contamination in sample cooler	170/03	Re Sample and test  All resample results met compliance.

### Non-Compliance

Legislation	requirement(s) system failed to meet	duration of the failure (i.e. date(s))	Corrective Action	Status
There were no Non-Compliance incidents reported during the reporting period.				

### Non-Compliance Identified in a Ministry Inspection:

Legislation	requirement(s) system failed to meet	duration of the failure (i.e. date(s))	Corrective Action	Status
There were no actions identified in the received inspection report.				

### Community Complaints

Date yyyy/mm/dd	Location	Details of Complaint	Corrective Action Taken
2025/01/13	122 Dibble East	Low Pressure	Plumbing within Premise
2025/01/30	EDW/CAR	Low Pressure	Watermain Break
2025/05/01	216 North Square	Low Pressure	Curb stop not fully open
2025/10/14	721 Boundary Rd	Discoloured water	Internal Plumbing
2025/10/28	EDW/CAR	Low Pressure	Watermain Break
2025/12/08	EDW/CAR	Low Pressure	Watermain Break
2025/12/08	Wellington House	Low Pressure	Watermain Break
2025/12/09	292 Russel St	No Water	No Issue

\*Community complaints were received by the Town Staff

## Flows


Prescott’s drinking water system is operating on average under half the rated capacity.

### Raw Water Flows

The Raw Water flows are regulated under the Permit to Take Water. 2025 Raw Flow Data was submitted to the Ministry electronically under permit #7246-DBCSX2. The confirmation and a copy of the data that was submitted are attached in Appendix A.


#### Total Monthly Flows (m3/d)

Max Allowable PTTW



#### Monthly Rated Flows (L/min)

Max allowable rate - PTTW




**Treated Water Flows**


The Treated Water flows are regulated under the Municipal Licence.

**Monthly Rated Flows**

Rated Capacity - MDWL



**Annual Total Flow Comparison**



## Regulatory Sample Results Summary

### Microbiological Testing

	# of Samples Collected	Range of E.Coli Results		Range of Total Coliform Results		# of HPC Samples	Range of HPC Results	
		Min #	Max #	Min #	Max #		Min #	Max #
Raw Water	53	0	18	0	137	0		
Treated Water	55	0	1	0	9	53	< 10	70
Distribution Water	223	0	2	0	17	53	< 10	1400

### Operational Testing

Parameter & Sample Type	No. of Samples Collected	Range of Results		
		Minimum	Average	Maximum
Turbidity; On-Line (NTU)- Filt1	8760	0.00	0.05	0.65
Turbidity; On-Line (NTU)- Filt2	8760	0.00	0.04	2.99
Turbidity; On-Line (NTU)- Filt3	8760	0.01	0.08	3.02
Turbidity; On-Line (NTU)- RW	8760	0.00	1.04	9.99
Turbidity; On-Line (NTU)- TW	8760	0.04	0.06	3.01
Fluoride Residual; On-line (mg/L)- TW	8760	0.01	0.51	1.29
Free Chlorine Residual; In-House (mg/L)- DW1	52	0.65	1.52	2.13
Free Chlorine Residual; On-Line (mg/L)- DW	8760	0.50	1.38	2.13
Free Chlorine Residual; In-House (mg/L)- DW2	52	0.51	1.35	1.87
Free Chlorine Residual; In-House (mg/L)- DW3	52	0.43	1.18	1.90
Free Chlorine Residual; In-House (mg/L)- DW4	52	0.63	1.44	2.00
Free Chlorine Residual; In-House (mg/L)- TW	52	1.32	1.69	2.11
Free Chlorine Residual; On-Line (mg/L)- TW	8760	1.10	1.69	4.88

NOTE: spikes recorded by on-line instrumentation were a result of air bubbles and various maintenance/calibration activities. All spikes are reviewed for compliance with O.Reg 170/03

### Inorganic Parameters

These parameters are tested as a requirement under 170/03. Sodium and Fluoride are required to be tested every 5 years. Nitrate and Nitrite are tested quarterly and the metals are tested annually as required under 170/03. In the event any of the parameters exceed half of the maximum allowable concentration the parameter is required to be sampled quarterly.

- MAC = Maximum Allowable Concentration as per O.Reg 169/03
- MDL = Method Detection Limit

Treated Water	Sample Date (yyyy/mm/dd)	Sample Result	MAC	No. of Exceedances	
				MAC	1/2 MAC
Antimony: Sb (ug/L) - TW	2025/01/13	0.1	6	No	No
Arsenic: As (ug/L) - TW	2025/01/13	0.3	10	No	No
Barium: Ba (ug/L) - TW	2025/01/13	22	1000	No	No
Boron: B (ug/L) - TW	2025/01/13	22	5000	No	No
Cadmium: Cd (ug/L) - TW	2025/01/13	< MDL 0.015	5	No	No
Chromium: Cr (ug/L) - TW	2025/01/13	< MDL 1	50	No	No
Mercury: Hg (ug/L) - TW	2025/01/13	< MDL 0.02	1	No	No
Selenium: Se (ug/L) - TW	2025/01/13	< MDL 1	50	No	No
Uranium: U (ug/L) - TW	2025/01/13	0.2	20	No	No
<b>Additional Inorganics</b>					
Fluoride (mg/L) - TW	2019/01/14	0.4	1.5	No	No
Nitrate : (mg/L) - TW	2025/01/06	0.25	10	No	No
Nitrate : (mg/L) - TW	2025/04/07	0.32	10	No	No
Nitrate : (mg/L) - TW	2025/07/07	0.21	10	No	No
Nitrate : (mg/L) - TW	2025/10/06	0.14	10	No	No
Nitrite : (mg/L) - TW	2025/01/06	< MDL 0.05	1	No	No
Nitrite : (mg/L) - TW	2025/04/07	< MDL 0.05	1	No	No
Nitrite : (mg/L) - TW	2025/07/07	0.08	1	No	No
Nitrite : (mg/L) - TW	2025/10/06	< MDL 0.05	1	No	No
Sodium / Na (mg/L) - TW	2024/01/02	15.1	20*	No	Yes

\*There is no MAC for Sodium. The aesthetic objective for sodium in drinking water is 200 mg/L. The local Medical Officer of Health should be notified when the sodium concentration exceeds 20 mg/L so that this information may be communicated to local physicians for their use with patients on sodium restricted diets.

#### Schedule 15 Sampling:

The Schedule 15 Sampling is required under O.Reg 170/03. This system is under reduced sampling. Lead was sampled in 2025 due to be sampled 2028.

Distribution System	Number of Sampling Points	Number of Samples	Range of Results		MAC (ug/L)	Number of Exceedances
			Minimum	Maximum		
Alkalinity (mg/L)	6	6	87	91	N/A	N/A
pH	3	3	7.93	8.17	N/A	N/A
Lead (ug/l)	3	3	0.02	0.11	10	0

### Organic Parameters

These parameters are tested annually as a requirement under O.Reg 170/03. In the event any of the parameters exceed half of the maximum allowable concentration the parameter is required to be sampled quarterly.

Treated Water	Sample Date (yyyy/mm/dd)	Sample Result	MAC	# of Exceedances	
				MAC	1/2 MAC
1,1-Dichloroethylene (ug/L)-TW	2025/01/13	< MDL 0.5	14	No	No
1,2-Dichlorobenzene (ug/L)-TW	2025/01/13	< MDL 0.5	200	No	No
1,2-Dichloroethane (ug/L)-TW	2025/01/13	< MDL 0.5	5	No	No
1,4-Dichlorobenzene (ug/L)-TW	2025/01/13	< MDL 0.5	5	No	No
2,3,4,6-Tetrachlorophenol (ug/L)-TW	2025/01/13	< MDL 0.2	100	No	No
2,4,6-Trichlorophenol (ug/L)-TW	2025/01/13	< MDL 0.2	5	No	No
2,4-Dichlorophenol (ug/L)-TW	2025/01/13	< MDL 0.2	900	No	No
2,4-Dichlorophenoxy acetic acid (2,4-D) (ug/L)-TW	2025/01/13	< MDL 1	100	No	No
Alachlor (ug/L) -TW	2025/01/13	< MDL 0.3	5	No	No
Atrazine + N-dealkylated metabolites (ug/L)-TW	2025/01/13	< MDL 0.5	5	No	No
Azinphos-methyl (ug/L)-TW	2025/01/13	< MDL 1	20	No	No
Benzene (ug/L)-TW	2025/01/13	< MDL 0.5	1	No	No
Benzo(a)pyrene (ug/L)-TW	2025/01/13	< MDL 0.006	0.01	No	Yes
Bromoxynil (ug/L)-TW	2025/01/13	< MDL 0.5	5	No	No
Carbaryl (ug/L)-TW	2025/01/13	< MDL 3	90	No	No
Carbofuran (ug/L) -TW	2025/01/13	< MDL 1	90	No	No
Carbon Tetrachloride (ug/L) -TW	2025/01/13	< MDL 0.2	2	No	No
Chlorpyrifos (ug/L) -TW	2025/01/13	< MDL 0.5	90	No	No
Diazinon (ug/L)-TW	2025/01/13	< MDL 1	20	No	No
Dicamba (ug/L)-TW	2025/01/13	< MDL 1	120	No	No
Dichloromethane (Methylene Chloride) (ug/L)-TW	2025/01/13	< MDL 5	50	No	No
Diclofop-methyl (ug/L)-TW	2025/01/13	< MDL 0.9	9	No	No
Dimethoate (ug/L)-TW	2025/01/13	< MDL 1	20	No	No
Diquat (ug/L)-TW	2025/01/13	< MDL 5	70	No	No
Diuron (ug/L)-TW	2025/01/13	< MDL 5	150	No	No
Glyphosate (ug/L)-TW	2025/01/13	< MDL 25	280	No	No
Malathion (ug/L)-TW	2025/01/13	< MDL 5	190	No	No
Metolachlor (ug/L)-TW	2025/01/13	< MDL 3	50	No	No
Metribuzin (ug/L)-TW	2025/01/13	< MDL 3	80	No	No
Monochlorobenzene (Chlorobenzene) (ug/L)-TW	2025/01/13	< MDL 0.5	80	No	No

Treated Water	Sample Date (yyyy/mm/dd)	Sample Result	MAC	# of Exceedances	
				MAC	1/2 MAC
Paraquat (ug/L)-TW	2025/01/13	< MDL 1	10	No	No
PCB (ug/L)-TW	2025/01/13	< MDL 0.05	3	No	No
Pentachlorophenol (ug/L)-TW	2025/01/13	< MDL 0.2	60	No	No
Phorate (ug/L)-TW	2025/01/13	< MDL 0.3	2	No	No
Picloram (ug/L)-TW	2025/01/13	< MDL 5	190	No	No
Prometryne (ug/L)-TW	2025/01/13	< MDL 0.1	1	No	No
Simazine (ug/L)-TW	2025/01/13	< MDL 0.5	10	No	No
Terbufos (ug/L)-TW	2025/01/13	< MDL 0.5	1	No	No
Tetrachloroethylene (ug/L)-TW	2025/01/13	< MDL 0.5	10	No	No
Triallate (ug/L) -TW	2025/01/13	< MDL 10	230	No	No
Trichloroethylene (ug/L)-TW	2025/01/13	< MDL 0.5	5	No	No
Trifluralin (ug/L)-TW	2025/01/13	< MDL 0.5	45	No	No
Vinyl Chloride (ug/L)-TW	2025/01/13	< MDL 0.2	1	No	No
HAA Total (ug/L) Annual Average-DW2	2025	10.9	80	No	No
Trihalomethane: Total (ug/L) Annual Average-DW1	2025	43	100	No	No

MAC = Maximum Allowable Concentration as per O.Reg 169/03

MDL = Method Detection Limit

RAA = Running Annual Average

### Additional Legislated Samples

Document	Parameter	Limit (mg/L)	Result (mg/L)
MDWL # 161-101	Filter Backwash Supernatant Suspended Solids	Annual Average < 25	4.67
MDWL # 161-101	Filter Backwash Supernatant Total CL2	Annual Average 0.02	0.01

### Major Maintenance Summary

Work order	Description
4332315	ARIES Filter Upgrade (ongoing)
4335634	Alum Tanks Cleanout
4335634	Backwash Tank Cleaning/Inspection
4335638	Analyzer Sensors and Probes Purchased
4335640	Filter Media Anthracite Purchased
4335640	Rebuilt 3 low lift pumps
4335644	Filter Flow Control Valve and Supernatant Flow Control Valve purchased
4335645	Raw water reservoir cleanout/inspection
4335646	Electrical/Instrumentation- Analyzer sensors and controller purchase



<b>Work order</b>	<b>Description</b>
4335647	Building Maintenance-Windows install, filter influent 1 valve install
4335649	Furnace replacement
4335649	Level controllers and sensors purchased
4335653	Generator Maintenance
4335654	Lifting equipment purchased
4335658	SWAN AMI Trides RW Turbidity Analyzer purchased and installed
4382018	Captor system installed, dosing pump and chemical purchased

### **Distribution Maintenance**

<b>Date</b>	<b>Description</b>
2025/12/08	Watermain break – King Street
2025/11/25	Watermain break – Edward Street N
2025/10/28	Watermain break – King Street
2025/09/08	Watermain break – Irvine Drive
2025/01/31	Watermain break – Duke Street
2025/01/30	Watermain break – Russel Street

# Appendix A

## WTRS Data and Submission Confirmation



Ministry of the Environment,  
Conservation and Parks

| [WT DATA](#) | [USER PROFILE](#) | [CONTACT US](#) | [HELP](#) | [HOME](#) | [LOGOUT](#) |

Location: [WTRS](#) / [WT DATA](#) / [Input WT Record](#) WTRS-WT-008

**Water Taking Data submitted successfully.**

**Confirmation:**


Thank you for submitting your water taking data online.



Permit Number: 7246-DBCSX2  
Permit Holder: THE CORPORATION OF THE TOWN OF PRESCOTT.  
Received on: Jan 16, 2026 11:03 AM

This confirmation indicates that your data has been received by the Ministry, but should not be construed as acceptance of this data if it differs from that specified on the Permit Number, assigned to the Permit Holder stated above.

[Print Confirmation](#)   [Return to Main Page](#)

SELENA SHANE | 2026/01/16  
version: v5.0.0.01 (build#: 28)  
Last modified: 2021/09/22

 This site maintained by the Government of Ontario ©2026 Queen's Printer for Ontario



Ministry of the Environment,  
Conservation and Parks

| [WT DATA](#) | [USER PROFILE](#) | [CONTACT US](#) | [HELP](#) | [HOME](#) | [LOGOUT](#) |

Location: [WTRS](#) / [WT DATA](#) / [Input WT Record](#) WTRS-WT-008

**Water Taking Data submitted successfully.**

**Confirmation:**


Thank you for submitting your water taking data online.

Permit Number: 5506-9RMLKE  
Permit Holder: THE CORPORATION OF THE SEPARATED TOWN OF PRESCOTT.  
Received on: Jan 16, 2026 11:01 AM

This confirmation indicates that your data has been received by the Ministry, but should not be construed as acceptance of this data if it differs from that specified on the Permit Number, assigned to the Permit Holder stated above.

[Print Confirmation](#)   [Return to Main Page](#)

SELENA SHANE | 2026/01/16  
version: v5.0.0.01 (build#: 28)  
Last modified: 2021/09/22

 This site maintained by the Government of Ontario ©2026 Queen's Printer for Ontario